

Commonwealth of Virginia  
Division of Consolidated Laboratory Services

600 North 5th St.  
Richmond, Virginia 23219  
804-648-4480



**REPORT OF ANALYSIS**

Report Date: 09/06/2024  
DCLS LIMS #: E240804709

**Mail To**

WILDERNESS WATER TREATMENT PLANT  
35249 WILDERNESS SHORES WAY  
LOCUST GROVE, VA 22508

PWSID 7600023  
REGION 7

ATTN: [REDACTED]

**Sample Information**

DATE RECEIVED	08/28/2024 10:24	LOCATION	WTP
SAMPLING DATE	08/27/2024 17:30	FACILITY	IN001
COLLECTED BY	[REDACTED]	COMPLIANCE	N
SAMPLE MATRIX	DRINKING WATER	TYPE	SP
ORDERED TEST	206-103 HERBICIDE	CATEGORY	GE
PROJECT NAME	DW2024-Q3	ORDER NUMBER	102575

**Test Results**

APPROVED BY: [REDACTED], Group Manager      DATE APPROVED: 09/06/2024

<u>METHOD</u>	<u>PARAMETER</u>	<u>RESULT</u>	<u>PMCL</u>	<u>SMCL</u>	<u>ANALYSIS DATE</u>
<u>EPA 515.3</u>	Dalapon	< 3.0 ppb	200		08/29/2024
	2,4-D	< 3.0 ppb	70		08/29/2024
	Pentachlorophenol	< 0.3 ppb	1		08/29/2024
	Silvex	< 1.0 ppb	50		08/29/2024
	Dinoseb	< 1.0 ppb	7		08/29/2024
	Picloram	< 1.0 ppb	500		08/29/2024

**Explanation of Terms and Disclaimers**

PMCL is defined as the "Primary Maximum Contaminant Level." SMCL is defined as the "Secondary Maximum Contaminant Level". If blank, level not defined by EPA. Results denoted with an asterisk (\*) indicate that the PMCL is exceeded. Test Results meet requirements of NELAP. Non-NELAP accredited analyses noted by ^^. The results included on this report relate only to this specific sample and not to other samples tested from this sampling location.

**CONFIDENTIALITY NOTICE:** This report contains PRIVILEGED and CONFIDENTIAL INFORMATION. This report should not be reproduced, except in full, without the written approval of DCLS. If you have received this report in error, please notify DCLS immediately at (804) 648-4480 Ext. 171.